



**CITY OF NORWALK**  
**Aquifer Protection Agency**

www.norwalkct.org

P: 203-854-7744 / F: 203-854-7962

Norwalk City Hall  
Room 215  
125 East Avenue, PO Box 5125  
Norwalk, CT 06856-5125

February 5, 2018

[Facility Name]

**RE: Gas Station Facility  
, Norwalk, CT  
Replacement of underground storage tanks**

Dear Mr.:

As we have discussed, this gas station facility is located within the Aquifer Protection Area (APA) of the City of Norwalk and is a Registered Facility. Your firm has been retained to design plans for the replacement of the existing underground motor fuel tanks and piping with new tanks and piping.

Existing underground storage tanks (USTs) used to store hazardous materials within the APA may be replaced with certain conditions. As required by Section 12 (a)(3) of the Norwalk Aquifer Protection Area Regulations, USTs for hazardous materials shall not be replaced with larger tanks unless A) there is no more than 25% increase in volume of the larger replacement tank, and B) the larger replacement tank is a double-walled tank with co-axial piping, both meeting new installation component standards pursuant to §22a-449(d)-1(e) and §22a-449(d)-102 of the Regulations of Connecticut State Agencies, and with interstitial monitoring.

The design depicted on the plan entitled, "Proposed Fueling System Renovation", dated January 23, 2018, by Benesch is approved for implementation. Please note, all elements of the plan, including the installation of interstitial monitoring, must be completed as part of the tank replacement project.

Upon initiation of the site activities authorized herein, the facility owner thereby accepts and agrees to comply with the terms and conditions detailed above. All activities shall be conducted in compliance with the requirements of the Norwalk Aquifer Protection Area Regulations. Failure to meet the requirements of local and/or state Aquifer Protection Regulations shall result in formal enforcement action.

If there are any questions regarding the APA Regulations and their administration, please do not hesitate to contact me at 203-854-7744.

Sincerely,

Alexis Cherichetti  
Senior Environmental Officer

cc: